

Project Information

For: Sample Project
1234 82nd Avenue Suite # 203, Vero Beach, FL 32966
Phone: 772-473-7350

	Htg	Clg		Htg	Clg
Outside db (°F)	43	91	Inside db (°F)	70	75
Outside RH (%)	-	57	Inside RH (%)	-	50
Outside wb (°F)	-	78	Inside wb (°F)	-	63
Daily range (°F)	-	15	Design TD (°F)	27	16
Moisture diff. (gr/lb)	-	59			

Heating Equipment

Make	n/a
Model	n/a
Type	n/a
Efficiency	n/a
Heating Input	0 MBtuh
Heating Output	0 MBtuh
Humidifier	0 gpd
Leaving Air Temp	0 °F
Actual Heating Fan	0 cfm

Cooling Equipment

Make	n/a
Model	n/a
Type	n/a
COP / EER / SEER	0
Sensible Cooling	0 MBtuh
Latent Cooling	0 MBtuh
Total Cooling	0 MBtuh
Leaving Air Temp	0 °F
Actual Cooling Fan	0 cfm

Equipment Location	Sample
System Type	n/a
Fan Motor Heat Type	n/a
Fan & Motor Combined Efficiency	0 %
Static Pressure Across Fan	0 in H2O

NAME	Area ft ²	Heat Loss	Sensible Gain	Latent Gain	Htg cfm	Clg cfm	Time
SYSTEM 2	2198	21361	32144	13356	1750	1750	Aug 1600 LDT
SYSTEM 1	2198	20880	39858	13324	1750	1750	Aug 1600 LDT
Sample	4259	42241	72001	26680	3500	3500	Aug 1600 LDT

Project Information

For: Sample Project
1234 82nd Avenue Suite # 203, Vero Beach, FL 32966
Phone: 772-473-7350

	Htg	Clg		Htg	Clg
Outside db (°F)	43	91	Inside db (°F)	70	75
Outside RH (%)	-	57	Inside RH (%)	-	50
Outside wb (°F)	-	78	Inside wb (°F)	-	63
Daily range (°F)	-	15	Design TD (°F)	27	16
Moisture diff. (gr/lb)	-	59			

Heating Equipment

Make	Goodman Mfg.
Model	GSZ140601K
Type	Split ASHP
Efficiency	8.5 HSPF
Heating Input	
Heating Output	59.0 MBtuh @ 47°F
Humidifier	7.9 gpd
Leaving Air Temp	100.7 °F
Actual Heating Fan	1750 cfm

Cooling Equipment

Make	Goodman Mfg.
Model	GSZ140601K
Type	Split ASHP
COP / EER / SEER	14.0
Sensible Cooling	39.5 MBtuh
Latent Cooling	16.9 MBtuh
Total Cooling	56.5 MBtuh
Leaving Air Temp	55.0 °F
Actual Cooling Fan	1750 cfm

Equipment Location: SYSTEM 1
System Type: PEAKCV
Fan Motor Heat Type: PACKAGE
Fan & Motor Combined Efficiency: 0 %
Static Pressure Across Fan: 0 in H2O

NAME	Area ft ²	Heat Loss	Sensible Gain	Latent Gain	Htg cfm	Clg cfm	Time
BREAK	108	2209	2595	870	248	115	Aug 1600 LDT
IT	2	0	0	0	0	0	Aug 1600 LDT
RR	33	482	1004	131	75	49	Aug 1600 LDT
FILE STORAGE	169	1658	3002	1106	136	131	Aug 1600 LDT
OFFICE1	169	902	2712	1087	19	116	Aug 1600 LDT
OFFICE2	169	905	2775	1096	20	119	Aug 1600 LDT
RECEPTION/WAITING	460	4311	8725	2989	340	381	Aug 1600 LDT
OFFICE3	176	1994	3574	1161	183	157	Aug 1600 LDT
OFFICE4	159	2493	3337	1023	273	147	Aug 1600 LDT
CLA	14	0	0	0	0	0	Aug 1600 LDT
CLB	12	0	0	0	0	0	Aug 1600 LDT
AHU1	16	0	0	0	0	0	Aug 1600 LDT
RR2	51	363	843	102	56	41	Aug 1600 LDT
SHOWROOM A	582	5562	11291	3758	400	494	Aug 1600 LDT

SYSTEM 1	2191	20880	39858	13324	1750	1750	Aug 1600 LDT
----------	------	-------	-------	-------	------	------	--------------

SAMPLE

Project Information

For: Sample Project
1234 82nd Avenue Suite # 203, Vero Beach, FL 32966
Phone: 772-473-7350

	Htg	Clg		Htg	Clg
Outside db (°F)	43	91	Inside db (°F)	70	75
Outside RH (%)	-	57	Inside RH (%)	-	50
Outside wb (°F)	-	78	Inside wb (°F)	-	63
Daily range (°F)	-	15	Design TD (°F)	27	16
Moisture diff. (gr/lb)	-	59			

Heating Equipment

Make	Goodman Mfg.
Model	GSZ140601K
Type	Split ASHP
Efficiency	8.5 HSPF
Heating Input	
Heating Output	59.0 MBtuh @ 47°F
Humidifier	8.7 gpd
Leaving Air Temp	100.7 °F
Actual Heating Fan	1750 cfm

Cooling Equipment

Make	Goodman Mfg.
Model	GSZ140601K
Type	Split ASHP
COP / EER / SEER	14.0
Sensible Cooling	39.5 MBtuh
Latent Cooling	16.9 MBtuh
Total Cooling	56.5 MBtuh
Leaving Air Temp	55.0 °F
Actual Cooling Fan	1750 cfm

Equipment Location: SYSTEM 2
System Type: PEAKCV
Fan Motor Heat Type: PACKAGE
Fan & Motor Combined Efficiency: 0 %
Static Pressure Across Fan: 0 in H2O

NAME	Area ft ²	Heat Loss	Sensible Gain	Latent Gain	Htg cfm	Clg cfm	Time
SHOW ROOM B	16	12553	19434	8612	798	1027	Aug 1600 LDT
OFFICE7	16	1546	2972	1064	138	169	Aug 1600 LDT
OFFICE8	22	2822	3110	1428	316	173	Aug 1600 LDT
HARDWARE	118	1546	2259	769	176	131	Aug 1600 LDT
OFFICE6	230	2895	4368	1483	323	250	Aug 1600 LDT
AHU2	12	0	0	0	0	0	Aug 1600 LDT
SYSTEM 2	2068	21361	32144	13356	1750	1750	Aug 1600 LDT

Project Information

For: Sample Project
1234 82nd Avenue Suite # 203, Vero Beach, FL 32966
Phone: 772-473-7350

Zone: Sample **COOLING LOAD**

1. DESIGN CONDITIONS	at Aug 1600 LDT	Peak load at Aug 1600 LDT		
Inside: 75 °F	Outside: 91 °F	TD: 16 °F		
OutRH: 57 %	MoistDiff: 59.4 gr/lb	Mult: 1.0	Ins.wb	63 °F
			Sensible	Latent
2. SOLAR RADIATION THROUGH GLASS			1011	-
3. TRANSMISSION GAINS	Sensible		10629	-
Walls:	3574		-	-
Glass:	959		-	-
Doors:	103		-	-
Partitions:	0		-	-
Floors:	448		-	-
Ceilings:	5546		-	-
4. INTERNAL HEAT GAIN	Sensible	Latent	51945	6756
Occupants:	8444	756	-	-
Lights:	36485		-	-
Motors:	0		-	-
Appliances:	7016	0	-	-
5. INFILTRATION:	Outside air cfm:		0	0
6. SUBTOTAL:	Space load	Sensible	Latent	
Envelope		63586	6756	-
Less external		0	-	-
Redistribution		0	0	-
7. SUPPLY DUCT:			0	-
8. SUBTOTAL:	Space load + supply duct		63586	-
Actual cfm:	3500	TD:	20	-
9. VENTILATION:	Make-up air cfm:	494	8416	19924
10. RETURN AIR LOAD:	Lighting + prenum (net)		0	-
11. RETURN DUCT:			0	-
12. TOTAL LOADS ON EQUIPMENT:			72001	26680

HEATING LOAD

13. DESIGN CONDITIONS		Mult: 1.0	
Inside: 65 °F	Outside: 43 °F	TD: 27 °F	
14. TRANSMISSION LOSSES			20540
Walls:	6101		-
Glass:	1749		-
Doors:	187		-
Partitions:	0		-
Floors:	9231		-
Ceilings:	3272		-
15. INFILTRATION:	Outside air cfm:	25	755
16. SUBTOTAL:	Space load		21295
Envelope	21295		-
Less external	0		-
Less transfer	0		-
Redistribution	0		-
17. SUPPLY DUCT:			0
18. VENTILATION:	Make-up air cfm:	494	14659
19. HUMIDIFICATION			6287
Piping			0
20. RETURN DUCT:			0
21. TOTAL HEATING LOAD ON EQUIPMENT:			42241

Project Information

For: Sample Project
1234 82nd Avenue Suite # 203, Vero Beach, FL 32966
Phone: 772-473-7350

Zone: SYSTEM 1 COOLING LOAD

1. DESIGN CONDITIONS	at Aug 1600 LDT	Peak load at Aug 1600 LDT			
Inside:	75 °F	Outside:	91 °F	TD:	16 °F
OutRH:	57 %	MoistDiff:	59.4 gr/lb	Mult:	1.0
				Ins.wb	63 °F
				Sensible	Latent
2. SOLAR RADIATION THROUGH GLASS				853	-
3. TRANSMISSION GAINS	Sensible			6494	-
Walls:	1889			-	-
Glass:	762			-	-
Doors:	103			-	-
Partitions:	0			-	-
Floors:	448			-	-
Ceilings:	3292			-	-
4. INTERNAL HEAT GAIN	Sensible	Latent		28734	4382
Occupants:	5477	382		-	-
Lights:	18025			-	-
Motors:	0			-	-
Appliances:	5232	0		-	-
5. INFILTRATION:	Outside air cfm:			0	0
6. SUBTOTAL:	Space load	Sensible	Latent	36081	4382
Envelope		36081	4382	-	-
Less external		0		-	-
Redistribution		0	0	-	-
7. SUPPLY DUCT:				0	-
8. SUBTOTAL:	Space load + supply duct			36081	-
Actual cfm:	1750	at supply TD:		20	-
9. VENTILATION:	Make-up air cfm:			222	3777
10. RETURN AIR LOAD:	Lighting + prenum (net)			0	8942
11. RETURN DUCT:				0	-
12. TOTAL LOADS ON EQUIPMENT:				39858	13324

HEATING LOAD

13. DESIGN CONDITIONS	Inside: 65 °F	Outside: 43 °F	Mult: 1.0	TD: 27 °F	
14. TRANSMISSION LOSSES					10554
Walls:	2798				-
Glass:	1391				-
Doors:	187				-
Partitions:	0				-
Floors:	4444				-
Ceilings:	1734				-
15. INFILTRATION:	Outside air cfm:		25		755
16. SUBTOTAL:	Space load				11309
Envelope		11309			-
Less external		0			-
Less transfer		0			-
Redistribution		0			-
17. SUPPLY DUCT:					0
18. VENTILATION:	Make-up air cfm:		222		6579
19. HUMIDIFICATION					2991
Piping					0
20. RETURN DUCT:					0
21. TOTAL HEATING LOAD ON EQUIPMENT:					20880

Project Information

For: Sample Project
1234 82nd Avenue Suite # 203, Vero Beach, FL 32966
Phone: 772-473-7350

Zone: SYSTEM 2 COOLING LOAD

1. DESIGN CONDITIONS	at Aug 1600 LDT	Peak load at Aug 1600 LDT		
Inside: 75 °F	Outside: 91 °F	TD: 16 °F		
OutRH: 57 %	MoistDiff: 59.4 gr/lb	Mult: 1.0	Ins.wb	63 °F
			Sensible	Latent
2. SOLAR RADIATION THROUGH GLASS			158	-
3. TRANSMISSION GAINS	Sensible		4136	-
Walls:	1685		-	-
Glass:	196		-	-
Doors:	0		-	-
Partitions:	0		-	-
Floors:	0		-	-
Ceilings:	2254		-	-
4. INTERNAL HEAT GAIN	Sensible	Latent	28212	2374
Occupants:	2967	374	-	-
Lights:	18461	-	-	-
Motors:	0	-	-	-
Appliances:	1783	0	-	-
5. INFILTRATION:	Outside air cfm:		0	0
6. SUBTOTAL:	Space load	Sensible	Latent	
Envelope		27505	2374	-
Less external		0	-	-
Redistribution		0	0	-
7. SUPPLY DUCT:			0	-
8. SUBTOTAL:	Space load + supply duct		27505	-
Actual cfm:	1750	TD:	20	-
9. VENTILATION:	Make-up air cfm:		272	4639
10. RETURN AIR LOAD:	Lighting + prenum (net)		0	10982
11. RETURN DUCT:			0	-
12. TOTAL LOADS ON EQUIPMENT:			32144	13356

HEATING LOAD

13. DESIGN CONDITIONS		Mult: 1.0	
Inside: 65 °F	Outside: 43 °F	TD: 27 °F	
14. TRANSMISSION LOSSES			9986
Walls:	3303		-
Glass:	358		-
Doors:	0		-
Partitions:	0		-
Floors:	4787		-
Ceilings:	1538		-
15. INFILTRATION:	Outside air cfm:	0	0
16. SUBTOTAL:	Space load		9986
Envelope		9986	-
Less external		0	-
Less transfer		0	-
Redistribution		0	-
17. SUPPLY DUCT:			0
18. VENTILATION:	Make-up air cfm:	272	8080
19. HUMIDIFICATION			3295
Piping			0
20. RETURN DUCT:			0
21. TOTAL HEATING LOAD ON EQUIPMENT:			21361